

# Purpose and Statistics

Agigawa Dam was constructed at Agi River that confluents Kiso River at Ena City and Agigawa Dam is located 110 km upstream from the river mouth of Kiso River.

#### Purpose

#### (1) Flood control······

The function of flood control of Agigawa Dam is to reduce design flood discharge of 850m<sup>3</sup>/sec to 120m<sup>3</sup>/sec.

To protect Ena City and downstream area around Kiso River from flood damage, during the flood season, Agigawa Dam secures 16 million m<sup>3</sup> storage capacity which is equivalent to the one-third total storage capacity for flood control.

#### (2) Conservation of the river environment ......

Agigawa Dam supplies water to stabilize vested intake in Kiso River and to maintain the river environment.

### (3) Supply of new water services.....

By construction of Agigawa Dam, another 4.0m<sup>3</sup>/sec water is available to use in Tounou Area in Gifu Prefecture (5 cities and 1 town) and Aichi Canal Project benefited Area in Aichi Prefecture as drinking and industrial water.


Water supplemented districts	Tap water service	Industrial water service	Total
Tounou Area in Gifu Prefecture	Maximum 0.8 - 0.8	- 1	0.8
Aichi Canal Project benefited Area in Aichi Prefecture	Maximum 1.102	Maximum 2.098	3.2
Total	1.902	2.098	4.0

#### Statistics


Location	Higashino, Ena City, Gifu Prefecture
Name of the river —	Agi River, Kiso River system
Type of dam	ECRD (Earth Core Rock-fill Dam)
Total storage capacity ———	48,000,000m <sup>3</sup>
Effective storage capacity ———	44,000,000m <sup>3</sup>
Sediment storage capacity —	4,000,000m <sup>3</sup>
Flood control capacity ————	16,000,000m³
Water utilization capacity ——	28,000,000m3 (flood season)
	44,000,000m3 (non-flood season)
Dam height —————	101.5m
Crest Length —	363m
Volume of the dam —	4,900,000m <sup>3</sup>
Elevation of the dam crest —	
Catchment area	81.8km²
Reservoir area ————	
Available Depth————	49.0m
Surcharge water level ————	EL.412.0m
Normal water level —	EL.412.0m
Flood season control level ———	EL.400.5m
Lowest low water level —	EL.363.0m
Design flood discharge	850m³/s
Design maximum discharge -	120m³/s
Design flood discharge	2,000m³/s

### ■Dam distribution graph(m³/s)







Stirage capacity allocation graph



# Structure

# ■Top view







The state of the s			
Flood		Type	Sliding type high-pressure radial gate Width 5.0m x Height 5.0 1 gate
Control Outlet	Orifice	Water conduit pipe	Width 5.0m x Height 5.0m to 8.23m Pipe length 9.27m
Works	yate	Water discharge capacity	Q=195.m³/s at Limited water level during flood season of EL.400.5m
	Radial gate Spillway Flap gate	Type	Overflow type radial gate Width 8.2m x Height 9.925m 2 gates
Emergency		Water discharge capacity	Maximum Q=1,060m³/s
		Type	Box garter type flap gate Width 18.0m x Height 3.3m 2 gates
	gate	Water discharge capacity	Maximum Q=746m³/s

Selected	Intake tower	Selective intake (reinforced concrete independent vertical type	
intake	Type	Liner multistage roller gate	
facility	Conduit pipe	3 pipes (1 pipe is for power generation)	
Discharge valve	Type	Fixed cone type Diameter 0.600m 1 valve	
Emergency discharge valve	Type	High-pressure sliding gate Width 1.25m x Height 1.60m 1 valve	
	Water discharge capacity	Q=48m³/s (high pressure + fixed cone) at lowest water utilization level of EL.363.0m	


### Longitudinal section



### ■Geological section



#### ■Spillway front view



# Management system

The dam is equipped with various facilities and equipment to fulfill its functions.



## Communication facilities

- Multiplex
- communication facility Mobile radio facility
- Automatic telephone operation facility

### **Observation facilities**

- Telemeter rainfall observation facilityTelemeter water level observation facility
- Reservoir water gauge
- Weather observation facilityRadar rain gauge terminal device
- Dam body observation device
- Earthquake measuring device
- Water quality measuring device



## Power facilities

- Hydraulic power generation facility for management

  Sub station
- Emergency power facility Uninterrupted power facility

# **Patrol**

- Patrol boat
- Workboat
- Warning vehicle



Orifice gate Radial gate

facilities

•Flap gate



### Warning apparatus

- Water discharge warning station Electronic display
- Selected water intake facility Water discharge valve Emergency water

Low water

management facilities











## Monitoring facilities

- Water discharge alarm station
- Electronic display panel

# Water quality conservation facilities

- Secondary dam
- Deep layer aeration facility
  Surface layer aeration facility
- Bypass pipe line



# Management and operation



Agigawa Dam has three purposes 1) Flood control 2) Maintaining the river environment 3) Water supply.

To carry out these purposes, Agigawa Dam Operation and Maintenance Office is doing three management works below.

Collection of weather information and hydrological data

Checking facilities and equipment Report to related

organizations

Warning discharge and patrolling downstream

Start of discharge from the dam

Start of flood control

Completing flood control

related organizations

Moving on to the low water management

Low water management

- Collect flow data at the lower reference
- Calculate the amount of water to be supplied to the domestic water and to conserve the river environment.
- Discharge water




Maintenance and inspection of facilities

Flood control

operation


- Data verification, arrangement, and report
- Observation of the dam body behavior
- Patrolling around the reservoir
- Environment maintenance
- Maintenance and improvement construction
- Conservation and examination of water quality
- Management administration
- Public relations work and so on







# Warning Facilities and Hydrologic Measurement Facilities





Discharge warning station

There are ten stations in the downstream area of the dam to notify discharge from the dam to people who are in or around river.



Patrol and warning vehicle
Before the start of discharge
from the dam, vehicles patrol


along the river to check the river condition downstream and that nobody is in the river.




Discharge warning board


These boards are put up at downstream key points before Agi River confluents Kiso River.

# Water Quality Conservation





In the deep layer of a reservoir, concentration of dissolved oxygen tends to drop as a result of decomposition of organic substances and the deep layer aeration facility is used to improve this condition. In the structure, water of the deep layer is raised by blowing air into one of the two vertical cylinders and the water containing oxygen is sent to the deep layer through another cylinder.




# Surface layer aeration facility

In order to control the growth of plankton in the reservoir, this facility aerates surface layer of 50m diameter at the rainfall of 100mm/h.



Selective water intake facility

The reservoir stores warm water in the surface layer and cold water in the lower layer from spring to autumn. Usually, water in the surface layer is fetched and discharged from the reservoir. However, when the water quality in the surface layer deteriorates due to the outbreak of plankton, this facility can fetch and discharge comparatively cleaner water from the middle layer.





Hydraulic power generation facility for management

The hydraulic power generation facility for management of the Agigawa dam generates output power of up to 2,600kW using the water discharged from the reservoir. This power is used for managing the dam and the extra power is sold to the electric power company. This reduces the management cost.

### Specification of hydraulic turbine and power generator

Specification of hydraulic turbine		
Туре	Horizontal shaft Francis hydraulic turbine	
Maximum output	2,700kW	
Effective drop	66.98m (at maximum output)	
Maximum flow	4.7m³/s	
Rotational speed	600rpm	

Specification of power generator		
Туре	3 phase synchronous power generator	
Maximum output	2,600kW	
Voltage	6,600V	
Frequency	60Hz	

# Improvement of environment around reservoir

There are many places worth visiting around Agigawa Dam such as the exhibition pavilion, Hananashiyama Park, Nakanoshima Park etc. Various kinds of events are held at these places.

Also there are many sighiseeing sports not so far from Agigawa Dam such as Ena-kyo (Ena Valley), Iwamura Castle ruin and Taisyo outdoor museum etc. These sightseeing sports are attracting lots of tourist throughout the year.



Dam entry plaza





Hananashiyama park





Kobushi park (floating island park)





# **Events**

Agigawa Dam Operation and Maintenance Office organize a variety of events. In summer, "Dam visiting tour", "Inspection Gallery visiting tour" and "Reservoir cruse" are held and "One day excursion to Agigawa Dam" is held in autumn for the elementary school students who live just downstream from the Agigawa Dam area. "Memorial March" and "Agigawa Lake Road Race" are also held around Agigawa Dam.

10 Days for Contact with Forests and Lakes / Water Week




grabing fish



Releasing fish


**Exhibition** 

Pavilion





Gadgets for Q & A on water-related matters and Agigawa Dam



Reservoir cruse



**Exhibition Pavilion** 

# One Day Excursion to Agigawa Dam








# **Memorial March**






Natural Environment around Agigawa Dam Agigawa Dam, which is located in the suburb of Ena City, is surrounded by afforested cypress and deciduous broadleaved forests. They are good habitats for a variety of plants and animals.

Many different kinds of waterfowls such as ducks and mandarin ducks inhabit the reservoir and monkeys, antelopes inhabit the forests around Agigawa Dam.







# Agigawa Dam operation and maintenance office 2201-79 Aza Hananashiyama, Higashino, Ena City, Gifu Prefecture 509-7202



HP address http://www.water.go.jp/chubu/agigawa

E-mail address agigawa@dam.enat.jp